

Summarising the evidence base on the use of surface flow treatment wetlands for phosphorus removal

Dr Gabriela Dotro, Professor Bruce Jefferson, Dr Tao Lyu

Nature-based solutions for wastewater treatment and management





Constructed wetland



spaces





Bioswales









Natural wetlands

Manaroves Reforestation

Surface flow treatment wetlands for domestic wastewater treatment

(Free water surface treatment wetlands)



Case studies from around the world



Overall conclusion

There is strong evidence that surface flow wetlands can capture phosphorus from sewage but there are critical gaps in understanding the long-term storage mechanisms resulting in significant uncertainties regarding achievable effluent quality for secondary treatment applications, with a lower risk for tertiary or polishing applications.

Phosphorous removal performance

of the 44 tertiary treatment systems without upstream P removal produced annual average effluent TP ≤ 3 mg/L

96% of tertiary treatment systems have no start-up period

Annual average effluent TP < 1 mg/L (without upstream P removal) with Influent TP < 3.2 mg/L and TP load < 28.5 mg/m²/yr

Annual average effluent TP < 0.35 mg/L (with upstream P removal) with Influent TP < 0.75 mg/L

Seasonal performance:



of systems show **no seasonality** in TP effluent concentrations





of systems have stable annual average effluent TP over up to 30 year period

YEARS

30

System design



Research gaps

- To aid performance prediction design guidance needs to be developed based on target total phosphorus effluent quality.
- To investigate the numeric quantification of multiple benefits (e.g., carbon, biodiversity, biomass production), predicted changes in land use, and climate change.
- Other applications of surface flow treatment wetlands, including the targeting of other pollutants and further research on storm overflows treatment.

Next steps

Targeted work is needed to advance the understanding of phosphorus transformations in wetland systems. A UK and Ireland-wide co-ordinated trials effort for intensive monitoring and mechanistic research to develop inherently robust and resilient wetlands that minimise the environmental footprint of phosphorus capture from sewage is required.

Sponsored by: Anglian Water, Dwr Cymru Welsh Water, Environment Agency, Irish Water, Northumbrian Water, Severn Trent, South West Water, Southern Water, Thames Water, United Utilities, Wessex Water and Yorkshire Water.